

SS 13/3 – Smoke Curtains

Specified System Description

System Status

New

Modified

Removed

System Type

Insulated Smoke Curtains – Single

Smoke Curtains – Modular Shield

Other (specify):

System Interfacing

SS 2

SS 15/5

Other (specify):

Not applicable

Standards

Performance / Installation Standards

BS EN 12101-1:2005 Smoke and heat control systems, Specification for smoke barriers (Amendment 1, 2006).

AS 1668.3:2001 The use of ventilation and airconditioning in buildings, Part 3: Smoke control systems for large single compartments or smoke reservoirs.

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so (*Details provided*)

Other: (*specify*)

Inspection Standards

AS 1851:2012 (Amendment 1, 2016) – Section 13.

AS 1851:2012 – Section 13.

AS 1851:2005 (Amendment 2, 2008) – Section 5.

AS 1851:2005 (Amendment 1, 2006) – Section 5.

AS 1851:2005 – Section 5.

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (*Details provided*)

Other: (*specify*)

Maintenance Standards

AS 1851:2012 (Amendment 1, 2016) – Section 13.

AS 1851:2012 – Section 13.

AS 1851:2005 (Amendment 2, 2008) – Section 5.

AS 1851:2005 (Amendment 1, 2006) – Section 5.

AS 1851:2005 – Section 5.

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so (*Details provided*)

Other: (*specify*)

Inspections, Maintenance and Reporting

Minimum Inspection and Maintenance Procedures

Regular inspection, testing, planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document to ensure effective operation of system for the required duration in the event of a fire.

Inspection and Maintenance - Frequency and Responsibility

Depending on the type of installation and its performance standard:

Six Monthly and Annually: by IQP

Standard / Other document (*specify*):

Inspections and Maintenance for Interfaced Systems

Annual Inspection: by IQP

The system is connected to other specified systems, therefore testing of the interface between the two systems will be carried out annually.

The system is NOT connected to other specified systems.

Reporting:

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out including dates, works undertaken, faults found, remedies applied and the name of the person who performed the work.
- Form 12A provided annually by the IQP.

Record No: 22209237

Date: 31 January 2023